

#### Order No. 292617

## Product

Applicant

Manufacturer

Factory

Ratings

Trade mark

Model / Type Ref.

Principal characteristics

A sample of the product was tested and found to be in conformity with Validity

Additional information

Additional model(s)

CERTIFICATE	
No. P15220114	



	DC-DC power supply for building-in	
	Astec International Ltd. 16th Floor, Lu Plaza, 2 Wing Yip Street, Kwun Tong, Kowloon, Hong Kong	
	Astec International Ltd. 16th Floor, Lu Plaza, 2 Wing Yip Street, Kwun Tong, Kowloon, Hong Kong	
	Zhongshan General Carton Box Factory Co., Ltd. No. 62 Qi Guan Road West, Shiqi District, Zhongshan City, Guangdong, 528400 China	
	DC-input: 28A, -4060V or 24A, -4860V	
	DS850DC-3	
s	CI. I. DC-outputs 70A MAX +12V, 6A MAX +3.3Vsb. Maximum combined output power is 850W.	
ct was tested formity with	OFF EN 60950-1:2006;A11;A1;A12;A2	
	This certificate documents conformity with the standards shown, and also applies as license for use of Nemkos name and certification mark. The certificate and license is valid as long as the applicable conditions are complied with, and provided that any changes to the product are notified to Nemko for acceptance prior to implementation. New standards or amendments to the standards may imply that the product design must be updated and/or that re-testing and re-certification is necessary.	
	See next page(s)	
	The abovementioned certified equipment complies with current regulatory requirements regarding electrical safety in Norway and other EU/EEA member states, as far as this can be checked. Compliance with requirements regarding building-in, protection against electric shock and Electromagnetic Compatibility (EMC) must be checked when the equipment is built-in a completed product or forme a part of a complete member.	

See next page(s)

product or forms a part of a complete system.

Date of issue 14-08-2015

Nastavan Vendoodi

Nastaran Vadoodi Certification Department

#### Nemko AS Gaustadalléen 30, P.O. Box 73 Blindern, 0314 Oslo, Norway TEL +47 22 96 03 30 FAX +47 22 96 05 50 EMAIL info@nemko.com ENTERPRISE NUMBER NO974404532



### Order No. 292617

# CERTIFICATE

No. P15220114



Product	DC-DC power supply for building-in
Pos. No	1
Model / Type Ref.	DS850DC-3-003
Trade mark (if different from page 1)	
Rating	DC-input: 24A, -4860 V
Principal characteristics	CI. I. DC-outputs 70A MAX +12V, 4A MAX +5Vsb. Maximum combined output power is 850W.
Product	DC-DC power supply for building-in
Pos. No	2
Model / Type Ref.	DS850DC-3-004
Trade mark (if different from page 1)	
Rating	DC-input: 28A, -4060V or 24A, -4860V
Principal characteristics	Cl. I. DC-outputs 70A MAX +12V, 6A MAX +3.3Vsb. Maximum combined output power is 850W.
Product	DC-DC power supply for building-in
Pos. No	3
Model / Type Ref.	DS650DC-3
Trade mark (if different from page 1)	
Rating	DC-input: 21A, -4060 V
Principal characteristics	Cl. I. DC-outputs 53A MAX +12V, 6A MAX +3.3Vsb. Maximum combined output power is 650W.
Product	DC-DC power supply for building-in
Pos. No	4
Model / Type Ref.	DS650DC-3-002
Trade mark (if different from page 1)	
Rating	DC-input: 21A -4060V
Principal characteristics	Cl. I. DC-outputs 53A MAX +12V, 4A MAX +5Vsb. Maximum combined output power is 650W.
Product	DC-DC power supply for building-in
Pos. No	5
Model / Type Ref.	DS650DC-3-003
Trade mark (if different from page 1)	
Rating	DC-input: 21A, -4060 V
Principal characteristics	CI. I. DC-outputs 53A MAX +12V, 6A MAX +3.3Vsb. Maximum combined output power is 650W.

Date of issue 14-08-2015

Nastavan Vendoodi

Nastaran Vadoodi Certification Department

#### Nemko AS

Gaustadalléen 30, P.O. Box 73 Blindern, 0314 Oslo, Norway TEL +47 22 96 03 30 FAX +47 22 96 05 50 EMAIL info@nemko.com ENTERPRISE NUMBER NO974404532